

MEETING NOTES

Meeting Date : April 15, 2009 Project : UO Lewis Integrative Science Building
Author : Regina Filipowicz Job No. : THA Project 0810
Re : Imaging Lab User Group SD Meeting 1

Present:

User Group Members

Scott Frey, Psychology / LCNI
Jolinda Smith, LCNI
Helen Neville, Psychology (partial)
Jennifer Pfeifer, Psychology (partial)

UO Representatives

Fred Tepfer
Emily Eng

Consultants

Chuck Cassell, HDR, lab planning principal
Regina Filipowicz, HDR, lab planner
Becca Cavell, THA project manager

Summary Notes

1. Chuck walked through the current designs with the Users discussing pro and cons of each.
2. Imaging Center layout No. 3 seemed to be the preferred layout – *refer to Figure 1*
3. Human Prep space is primarily a paperwork space and can be smaller, roughly 64 sf
4. Jolinda indicated the Electronics Shop is much too small and needs to be larger, *refer to Figure 1.*
5. MRI Equipment Room requires a direct door from the exterior for equipment and LHe deliveries.
6. Chuck pointed out there should be a removable panel at the south wall of the MRI Bay for the inevitability of repairing and/or replacing the magnet.
7. Scott mentioned that it's critical we bring a third party shielding consultant on board, preferably one with MRI focused consulting.

END OF NOTES

NOTE: Attention Attendees! Please review these notes carefully as they will form the basis of future work on this project. If you feel that anything is incorrect or incomplete, please call the author at 503-227-1254.




Figure 1

NOTE: Attention Attendees! Please review these notes carefully as they will form the basis of future work on this project. If you feel that anything is incorrect or incomplete, please call the author at 503-227-1254.